



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 17, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCCP20240808

Property Address: 911 SHAW RD, PUYALLUP, WA 98372; 901 SHAW RD, PUYALLUP, WA 98372; 813 SHAW RD, PUYALLUP, WA 98372;

Contractor: MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

To construct: Phase 2 site development of East Town Crossing including grading, storm drainage, parking, and utilities per plans. - 731 SHAW RD

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 6/16 - Building "F" fire line was hydro tested @ 200psi for 2hrs with zero drop. (PASSED)
- Building "F" fire line was bag flushed from the FDC and building flange. 2-2.5" hoses on the FDC and 2-2.5" hoses on the floor flange. Flushed 3 times @ 15min. each. (PASSED)
- Building "F" water service was visually inspected for leaks. (PASSED)
6/17 - Building "E" water service was visually inspected for leaks. (PASSED)
- Building "F" FDC had the ball drip installed. - Building "C" fire line was bag flushed from the FDC and building flange. 2-2.5" hoses on the FDC and 2-2.5" hoses on the floor flange. Flushed 3 times @ 15min. each. (PASSED) - Building "C" FDC had the ball drip installed.

Corrections:

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little
Development Engineering Inspector
JLittle@PuyallupWA.gov
(253) 244-0387