



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Permit Review Correction Letter

Permit Application #PRCTI20250697

June 23, 2025

The City has completed the review of the above-mentioned permit submittal. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Re-submittal Instructions

To resubmit, you must address all comments and upload a ~~Correction Response Letter~~ that states how the corrections have been addressed in your resubmitted documents. Avoid using "upload additional docs" unless there is NO submittal item available for your document. Please Note: If you have any questions about how to resubmit, please contact the permit center.

- 1 Log in to your permits portal and navigate to the status page for this permit under the "My Items" tab by selecting the "Upload Submittals" button under the permit number.
- 2 For each submittal item listed re-submit a new version of the submittal item by clicking the "New Version" button next to the file name of the original file submitted. DO NOT click the 'browse' button unless the document you are submitting for that submittal item is not a new version of the originally submitted document. Click 'Upload Documents' at bottom of the page.
- 3 If any re-submittal fees have been assessed, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

Corrections

Corrections to be addressed on the next set of resubmitted plans:

Building Review	Stan Kinnear		SKinnear@puyallupwa.gov
<ul style="list-style-type: none">- Provide all required backflow prevention devices that are required the 2021 Washington State Plumbing Code and Washington State Department of Health to prevent cross connections. This should include Beverage Dispensers, Dishwashers, Ice Makers, Kitchen Equipment, etc. [CONSTRUCTION PLAN SET; 2025\PRCTI20250697\ConstructionPlanSet - Wienerschnitzel - South Hill TI Arch Plan PERMIT SUBMITTAL SET 05-27-25 (DO NOT USE NOT PLATTEN).pdf; pg. 12]- Clarify if the refrigeration system will be replaced and if any piping will be replaced. all components that are being replaces will need to meet the 2021 Washington State Mechanical Code. [CONSTRUCTION PLAN SET; 2025\PRCTI20250697\ConstructionPlanSet - Wienerschnitzel - South Hill TI Arch Plan PERMIT SUBMITTAL SET 05-27-25 (DO NOT USE NOT PLATTEN).pdf; pg. 15]- Notate if the engineer will need to review the refrigeration system due to weight of the new system. [CONSTRUCTION PLAN SET; 2025\PRCTI20250697\ConstructionPlanSet - Wienerschnitzel - South Hill TI Arch Plan PERMIT SUBMITTAL SET 05-27-25 (DO NOT USE NOT PLATTEN).pdf; pg. 15]- If the roof top unit is being replaced, reflect what if any weight difference there is between the existing and the proposed. Show the location of the the new roof top unit on the plans to show proper clearances. [CONSTRUCTION PLAN SET; 2025\PRCTI20250697\ConstructionPlanSet - Wienerschnitzel - South Hill TI Arch Plan PERMIT SUBMITTAL SET 05-27-25 (DO NOT USE NOT PLATTEN).pdf; pg. 21]- Indicate on the plans if existing ducting is staying in place or if the ducting will be modified to accommodate the new layout. [CONSTRUCTION PLAN SET; 2025\PRCTI20250697\ConstructionPlanSet - Wienerschnitzel - South Hill TI Arch Plan PERMIT SUBMITTAL SET 05-27-25 (DO NOT USE NOT PLATTEN).pdf; pg. 21]			

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, if "Resolved" means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City's permit portal](#).

Condition Category	Condition	Department	Condition Status
-----------------------	-----------	------------	---------------------

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center
(253) 864-4165 option 1
permitcenter@puyallupwa.gov