



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 24, 2025

Inspection Result: NOT READY

Permit Number: PRMU20240400

Property Address: 3002 E PIONEER, BUILDING F, PUYALLUP, 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: ISSUED AS BUILDING C 3-story apartment building - EAST TOWN
CROSSING - REASSIGNED AS 3002 E PIONEER - BLDG F * REVISION (1) -
2/26/2025 - ENGINEERED TRUSS DRAWINGS

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: complete all A35's at shear walls, head out of floor joist at plumbing, draft stop ,firestop, nailing of hardware, and missing studs as discussed with contractor prior to next inspection.

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684