



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 30, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRMU20240400

Property Address: 3002 E PIONEER, BUILDING F, PUYALLUP, 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: ISSUED AS BUILDING C 3-story apartment building - EAST TOWN
CROSSING - REASSIGNED AS 3002 E PIONEER - BLDG F * REVISION (1) -
2/26/2025 - ENGINEERED TRUSS DRAWINGS

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 pre insulation unit 106 ok behind meters with sk approval and studs replaced in bearing wall.

Sincerely,

Monty Johnson
Sr Building Inspector
Monty@PuyallupWA.gov
(253) 770-3326