



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 25, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRMU20240400

Property Address: 3002 E PIONEER, BUILDING F, PUYALLUP, 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: ISSUED AS BUILDING C 3-story apartment building - EAST TOWN

CROSSING - REASSIGNED AS 3002 E PIONEER - BLDG F * REVISION (1) -
2/26/2025 - ENGINEERED TRUSS DRAWINGS

On this day we have inspected your construction for **Mechanical Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 ; complete rough-in of ducts after rated ceiling is installed at mechanical soffits.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684