



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jun 26, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCTI20241902

**Property Address:** 4227 S MERIDIAN, Unit: E, PUYALLUP, WA 98373

**Contractor:** HORIZON RETAIL CONSTRUCTION, INC. 9999 E. EXPLORATION CT.  
STURTEVANT, WI 53177 (262) 638-6000

**To construct:** 1. NEW FIXTURE, FURNITURE, EQUIPMENT AND GRAPHICS INTERIOR PARTITIONS AND DOORS FINISHES IN ALL AREAS CEILING IN ALL AREAS LIGHTING IN ALL AREAS PLUMBING FIXTURES ELECTRICAL SYSTEM MECHANICAL SYSTEM FIRE SAFETY EQUIPMENT EGRESS - T  
MOBILE - 4227 S MERIDIAN, Unit: E, PUYALLUP, WA 98373 \* REVISION  
(1) - 3/20/2025 - FIELD CONDITION THAT REQUIRES 2 RTU'S TO BE  
RELOCATED. \* REVISION (2) - 5/16/2025 - BASED ON SITE CONDITIONS  
(SPACE LIMITATIONS WITH HVAC DUCTWORK) THE ROOF FRAMING  
PLAN, DETAILS, AND CALCS HAVE BEEN UPDATED.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; complete correction from last mechanical inspection. (items - 2,3,5,6,)
  - 2 ; secure RTU'S to curb adapter as discussed with contractor.
- T.C.O. approved for 10 working days from 6-26-2025

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684