



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 26, 2025

Inspection Result: **FAILED**

Permit Number: PRMU20240139

Property Address: 3002 E PIONEER, BUILDING G, PUYALLUP, WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: ISSUED AS BUILDING B 3-story apartment building with (24) 2-bedroom/2-bathroom units ETC - REASSIGNED AS 3002 E PIONEER - BLDG G * REVISION (1) - 1/30/2025 - ENGINEERED TRUSS DRAWINGS

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 ; complete fire tape and fire caulking at rated lids of mechanical soffits in all units. not ready

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684