



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 30, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRFUP20250407

Property Address: 1115 E MAIN, PUYALLUP, WA 98372;

Contractor: PSE - INFRASOURCE 3130 S 38TH ST TACOMA, WA 98409

To construct: 106401523- (NIGHT) WORK IN ROW TO INSTALL NEW LONG SIDE GAS SERVICE. C&C 1-1/4" PE SVC. WINDOW FOR COMMS, WATER, SEWER, AND STORM. FIVE 4X4 ASPHALT CUTS. ONE 4X3 ASPHALT CUT.

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: AA Asphaltting took the eastbound lane on E. Main at 8:15 AM. The temporary patch was demoed, the base was compacted, and the edges were cleaned and tacked. The patch was paved back in three lifts for a total of 8 1/2" depth, with the first lift installed at 9 AM. The final lift was completed by 9:30 a.m.

Corrections:

Sincerely,

Cheryl Trimble
Development Engineering Inspector
CTrimble@PuyallupWA.gov
(253) 290-9834