

**Development & Permitting Services** 

333 S. Meridian, Puyallup, WA 98371

www.cityofpuyallup.org

Permit No: PRFA20250795

# FIRE ALARMS

Puyallup, WA

Job Address Address: 3002 E PIONEER, BUILDING F, PUYALLUP, 98372 **ISSUED** Parcel # 0420264021 July 07, 2025 Owner EAST TOWN CROSSING LLC 1001 SHAW RD PUYALLUP, WA 98372 **Applicant** Amy Henderson 5009 Pacific Hwy E., Suite 13 Fife, WA 98424 amy@maxpowernw.com Contractor MAX POWER ELECTRIC PO BOX 880 MILTON, WA 98354 (253) 838-4400 AMY@MAXPOWERNW.COM WA L&I #: **Description of Work** Building C @ East Town Crossing - Fire Alarm System for new residential - multi unit. - " ISSUED AS BUILDING C - EAST TOWN CROSSING - REASSIGNED AS 3002 E PIONEER - BLDG F " **Permit Types** Fire Alarms Expiration Date: January 03, 2026 Total ESU's

## REQUESTING REQUIRED INSPECTIONS

A list of required inspections can be found on the permitting portal. Log in to your portal account, click on my items, and expand My Building Permit application, My Engineering Permit application, or My Fire Permit application depending on your permit type. Then locate your permit number and click on "request inspection". This will pull up a list of inspection types associated with your permit. Click on the desired inspection type and then click Next Step to begin the inspection request process.

**Building Components:** 

ı	Quantity	Units	Description		
	121	DEVICES	Fire Alarm and Detection System and		
			Related Equipment, New		
				Total Value of Work:	\$0.00

## **Standard Conditions:**

Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling. Inspections are Monday - Thursday, no friday inspections

- Provide plans and permit on site for inspection.
- Complete labor and industries inspections prior to requesting city inspection.
- Device maps required at the annunciator and fire alarm panel prior to calling in final. The annunciator map will need to be weatherproof.
- Total coverage is required, subject to field inspection. Comply with NFPA 72, 2019
- Fire alarm system shall be placarded per NFPA 72. The UL certificate shall be posted at time of final inspection. The system will need to be UL certified.
- A pre-test shall be conducted and a printout of the location of the device, point number and descriptor shall be furnished to the inspector at final. Labeling of all devices above and below ceiling required.
- Fire sprinkler tamper valves and PIV will be required to be tested at inspection. Fire sprinkler contractor to be onsite.
- Due to unforeseeable construction design, all device locations to be field verified for compliance.

Schedule your inspection online through the city of puyallup online permit system after requesting appointment from inspector. Fire Inspections are Monday – Thursday there will be no inspections on Fridays.

David Drake 253-864-4171 ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

## Conditions

The items listed in the table below are outstanding conditions that need to be resolved prior to occupany and/or final inspection.

Condition	Condition	Department	Condition
Category			Status

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Amy Henderson