



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jul 08, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRMU20240400

**Property Address:** 3002 E PIONEER, BUILDING F, PUYALLUP, 98372

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** ISSUED AS BUILDING C 3-story apartment building - EAST TOWN  
CROSSING - REASSIGNED AS 3002 E PIONEER - BLDG F \* REVISION (1) -  
2/26/2025 - ENGINEERED TRUSS DRAWINGS

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 ; complete install of all RC channel as discussed with contractor.

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684