



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jul 11, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** E-20-0612

**Property Address:** 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374;

**Contractor:** PEASE / SONS PO BOX 44100 TACOMA, WA 98444 Brandon Haskins  
10601 Waller Rd E Tacoma, WA 98446 (253) 370-6559

**To construct:** CIVILS ~ FERRUCCI JHS REMODEL & ADDITION\*\*2021 STORM SDC FEES  
UPDATED\*\*STOP WORK ORDER removed on 03/29/2023 by username  
'Jeff Hill'.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Replaced storm air testing:

CB 114 to 115 PASS

CB 115 to 104 PASS

CB 104 to SF 04 PASS

SF 04 to CB 112 FAIL

SF 04 to CB 109 PASS

CB 107 to 113 PASS

**Corrections:**

Sincerely,

Jeff Hill

Development Engineering Inspector

[Jhill@PuyallupWA.gov](mailto:Jhill@PuyallupWA.gov)

(253) 204-5633