

WATER

Plumbing Fixture Plan Review

System Development Charge Calculation Sheet Based on Fixture Unit Weight (FUW)

All water systems shall have water hammer arrestors and shall be accessible - Sec: 609.10 UPC

Appliances, Appurtenances or Fixtures	No Change to Existing Fixture	Existing Fixture Relocated or Replaced	Existing Fixture Removed Not Replaced	New Fixture Added Not a Replacement	FUW Count For Each Item	Total FUWs City to complete
Bathtub or combination bath/shower					4	
Bidet - Private					1	
Clothes washer					4	
Dental unit, cuspidor					1	
Dishwasher, domestic					1.5	
Drinking fountain or water cooler - Private/Public				2	0.5	
Drinking fountain or water cooler - Assembly					0.75	
Hose bib				1	2.5	
Hose bib, each additional				1	1	
Lavatory (bathroom sink)				6	1	
Pedicure basin					1	
Shower, per head				8	2	
SINKS						
Bar sink - Private					1	
Bar sink - Public					2	
Clinic Faucet - Public					3	
Clinic flushometer valve with/without faucet - Public					8	
Kitchen, domestic					1.5	
Laundry					1.5	
Service or mop basin - Private					1.5	
Service or mop basin - Public				1	3	
Wash-up, each set of faucets - Public					2	
Wash fountain, circular spray - Public					4	
URINALS					2	
Urinal, 1.0 GPF Flushometer valve - Public				2	4	
Urinal, 1.0 GPF Flushometer valve - Assembly					5	
Urinal, greater than 1.0 GPF Flushometer valve - Public					5	
Urinal, greater than 1.0 GPF Flushometer valve - Assembly					6	
Urinal, flush tank – Private or Public					2	
Urinal, flush tank - Assembly					3	
WATER CLOSETS						
Water closet, 1.6 GPF Gravity tank/Flushometer tank – Private/Public					2.5	
Water closet, 1.6 GPF Gravity tank/Flushometer tank – Assembly					3.5	
Water closet, 1.6 GPF Flushometer valve – Private/Public				6	2.5	
Water closet, 1.6 GPF Flushometer valve – Assembly					3.5	
Water closet, greater than 1.6 GPF Gravity tank – Private					3	
Water closet, greater than 1.6 GPF Gravity tank – Public					5.5	
Water closet, greater than 1.6 GPF Gravity tank – Assembly					7	
Water closet, greater than 1.6 GPF - Flushometer valve - Private					7	
Water closet, greater than 1.6 GPF - Flushometer valve - Public					8	
Water closet, greater than 1.6 GPF - Flushometer valve - Assembly					10	
TOTALS						

Contact Engineering Services for current System Development fee information

FORM PREPARED BY: Matthew Epstein

DATE: 6/24/2025

TEL: (203) 604-4106

EMAIL: mepstein@gpinet.com

PRCTI20250853

System Development Charge Calculation Sheet Based on Fixture Unit Weight (FUW)

Contact Engineering Services for current System Development fee information

DATE: 6/24/2025

**City of Puyallup
Development
Engineering
ACCEPTED**

ycharitou
07/08/2025
8:09:34 AM

14.5 of the 26.5 available sewer credits from PRDE20240877 were redeemed on Boot Barn's tenant improvement permit PRCTI20240669. The 12 remaining sewer credits are hereby redeemed on permit PRCTI20250853. The total 84 FUW above will be reduced by 12 when calculating fees in the permitting portal. Only 72 sewer FUWs have been assessed.

