

Notes and details provided should be relevant to the current project. Keynotes have a number of page references that are not provided. Update notes and details to current scope. Any details that are needed should be provided.

(Sheet R141)

2 SET OWNER FURNISHED ROOFTOP COMPRESSOR RACK AND CONDENSER ON ROOF CURBS, SEE ARCHITECTURAL SHEET A140 FOR ROOF CURBS. 3 OWNER FURNISHED REFRIGERATION PIPE BOX, SEE ARCHITECTURAL SHEET A140 FOR INSTALLTION INSTRUCTIONS,

INSTALL A 12 PECE OF INSULATION ON ALL UNINSULATED

6 REFRICE TABLE SECURE PIPE

A. SEE SPECIFICATIONS FOR SPACING OF PIPE SUPPORTS.
SEE ARCHITECTURAL SHEET A140 FOR PIPE SUPPORT DETAIL.

ROOF BOX SCHEDULE		EQUIPMENT SYMBOL
BOX TYPE	DIMENSIONS W'X L'X D'	TOTAL QUANTITY
◈	18"×18"×24"	2
₿	24'×24'×24'	
©	24*x72*x24*	1
•	24"×90"×24"	-
€	24°×96°×24°	
€	24"×108"×24"	-
©	24"×120"×24"	-
⅌	24°×138°×24°	1

ALL WORK ON REFRIGERATION DRAWINGS SHALL BE COMPLETED BY TARGET APPROVED REFRIGERATION CONTRACTOR UNLESS NOTED OTHERWISE.



CTA ARCHITECTS ENGINEERS



PUYALLUP, WA

REFRIGERATION ROOF PLAN

R141