



4815 Center Street
Tacoma, WA 98409-2319
(253) 474-9449 / sittshill.com

Kathy A. Hargrave, PE
Larry G. Lindell, PE, SE
Michael A. McEvilly, PLS
Andrew J. Boileau, PE, SE
David C. Boileau, AIA
Donald C. Davis, PE

PRCP20250912

July 1st, 2025

Calculations required to be provided by
the Permittee on site for all Inspections

CARPORTS OF WASHINGTON, INC.
P.O. Box 2389
Buckley, Washington 98321

TO: Ms. Candy Ford

SUBJECT: ***EAST TOWN CROSSING CARPORTS – SPECIAL INSPECTION REQUIREMENTS
PUYALLUP, WASHINGTON
SITTS & HILL PROJECT #20,822***

Dear Ms. Candy Ford,


Per your request, we have reviewed the Special Inspection Requirements for the above noted carports.


Per the International Building Code (IBC) Section 312, the carports are classified as Occupancy Group U.
Per IBC Section 1704.2, Exception 2, no special inspections are required for this type of structure.

Therefore, no Special Inspections are required for the carports.

Please feel free to contact our office with any additional questions or comments regarding this project.

Sincerely,


Caleb Timmer, P.E., S.E.
Senior Project Engineer



07/01/2025

O:\20800\20822\Correspondence\Letters\2025-07-01 East Town Crossing Carports Special Inspection