



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 18, 2025

Inspection Result: NOT READY

Permit Number: PRMU20240401

Property Address: 3002 E PIONEER, BLDG E, PUYALLUP, WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: ISSUED AS BUILDING D 3-story apartment building - EAST TOWN
CROSSING - REASSIGNED AS 3002 E PIONEER - BLDG E * REVISION (1) -
04/21/2025 - ENGINEERED TRUSS DRAWINGS

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. complete insulation and frame corrections at pre-rock as back of electrical panel on 1st floor.

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684