


**sh** sitts&hill  
4815 Center Street  
Tacoma, WA 98409-2319  
(253) 474-9449 / sittshill.com

**PRCP20250899**

Kathy A. Hargrave, PE  
Larry G. Lindell, PE, SE  
Michael A. McEvilly, PLS  
Andrew J. Boileau, PE, SE  
David C. Boileau, AIA  
Donald C. Davis, PE

July 1<sup>st</sup>, 2025

CARPORTS OF WASHINGTON, INC.  
P.O. Box 2389  
Buckley, Washington 98321



TO: Ms. Candy Ford

SUBJECT: ***EAST TOWN CROSSING CARPORTS – SPECIAL INSPECTION REQUIREMENTS  
PUYALLUP, WASHINGTON  
SITTS & HILL PROJECT #20,822***

Dear Ms. Candy Ford,


Per your request, we have reviewed the Special Inspection Requirements for the above noted carports.


Per the International Building Code (IBC) Section 312, the carports are classified as Occupancy Group U. Per IBC Section 1704.2, Exception 2, no special inspections are required for this type of structure.

Therefore, no Special Inspections are required for the carports.

Please feel free to contact our office with any additional questions or comments regarding this project.

Sincerely,

  
Caleb Timmer, P.E., S.E.  
Senior Project Engineer



07/01/2025

O:\20800\20822\Correspondence\Letters\2025-07-01 East Town Crossing Carports Special Inspection