



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 22, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20250117

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 702-8193

To construct: Voluntary Seismic Upgrade of the entire building from a Category 2 to a Category 4 - COP PUBLIC SAFETY BUILDING * REVISION (1) - 6/24/2025
- BRB (BUCKLING RESTRAINED BRACES AND CONNECTIONS) SUBMITTAL
* REVISION (2) - 7/16/2025 - CD SET AS A REVISION TO THE CURRENT SET

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; framing of steel studs complete at BF#4 (6H) (6G)

2 ; welding approved per special inspection at columns of level 1 only- 8D west side of lobby only ,9C east side of lobby only, 8K ,6H,6G.

Corrections:

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 840-6684