



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 22, 2025

Inspection Result:

**PASSED W/
CONDITIONS**

Permit Number: PRCP20250695

Property Address: 3002 E PIONEER, PUYALLUP, WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: install pre-manufactured carport #5, which is near building 'G' and cover which covers 8 stalls - EAST TOWN CROSSING (3002 E PIONEER)

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: pending geo-tech approval for soil bearing of 2000 psf.

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684