



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jul 22, 2025

**Inspection Result:**

**PASSED W/  
CONDITIONS**

**Permit Number:** PRCP20250904

**Property Address:** 3002 E PIONEER, PUYALLUP WA 98372

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** Carport #7 of 17 proposed carports - EAST TOWN CROSSING -  
CARPORT 7 - (3002 E PIONEER)

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** pending geo-tech approval for soil bearing of 2000 psf

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)  
(253) 840-6684