

TRANSMITTAL FORM

Wright Roofing

PO Box 9339  
Tacoma WA 98490  
253-472-33321  
ryan@wrightroofingwa.com

PRRF20250950

PROJECT NAME	DATE OF SUBMISSION
Puyallup School Dist- Meeker Elementary	7/22/25
PROJECT MANAGER	TRANSMITTAL NUMBER
Ryan Lawson	1

TRANSMITTED TO: (NAME/ADDRESS)	City of Puyallup – Permitting      Skinnear@puyallupwa.gov
-----------------------------------	--

SUBJECT OF SUBMITTAL	SPECIFICATIONS
Permit Application # PRRF20250950 Corrections	Roofing Re-submittal

CHECK ONE OF THE FOLLOWING:

	Submittal Cover Page

CONTRACTOR NAME	SIGNATURE
Ryan Lawson	

COMMENTS	<p>Submittal Corrections Requested by AHJ- Provide supplemental Roof Assemblies testing for both roofing systems to confirm the Class of Fire Rating Specified in submittal.</p> <p>Re-submittal Changes-</p> <ul style="list-style-type: none"><li>1) Revised submittal Pages - Page 1 Low slope assembly info updated from Class B to Class A</li><li>2) Supplemental info added pages 2-5 and 6-16</li></ul>
----------	---