



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jul 31, 2025

**Inspection Result:** NOT READY

**Permit Number:** PRCA20231436

**Property Address:** 310 31ST AVE SE, PUYALLUP, WA 98374;

**Contractor:** SLETTEN CONSTRUCTION COMPANY PO BOX 2467 GREAT FALLS, MT 59403

**To construct:** RESUBMITTAL FOR PERMIT B-21-0905. TI UPDATES TO ONLINE GROCERY PICKUP; FIXTURE FINISHES UPDATES; 3,232 SF ADDITION TO EXISTING ~ WALMART \* REVISION (1) 2/27/2025 - RELOCATE LADDER FROM GROUND TO ROOF FOR SECURITY & SAFETY, SEE NARATIVE \* REVISION (2) - 7/3/2025 - ELECTRICAL REVISION TO INCLUDE THE NEW ENGINEER OF RECORD FOR THE DESIGN.

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 ; complete all framing requirement at new door opening as per city approved plans with special inspection report for welding, and epoxy at time of next inspection.  
not ready

Sincerely,

Shannon King



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684