



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 11, 2025                      **Inspection Result:**     **FAILED**

**Permit Number:** PRCTI20250537

**Property Address:** 302 33RD ST SE, PUYALLUP, WA 98372;

**Contractor:** DELANEY CONSTRUCTION LLC 635 TRADE CTR CHESTERFIELD, MO 63005

**To construct:** OFFICE TI; SCOPE TO INCLUDE BUILDING & MECH; EXISTING LARGE OFFICE SPACE- TO BE CONVERTED TO SEVERAL SMALL OFFICES; FULL HEIGHT PARTITIONS; CREATE ADDITIONAL OFFICE & STORAGE SPACE; REVISED ALL LIGHTING BUILD/MECH COMBINED

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1; remove screws from top track to ceiling grid.

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)