



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 12, 2025

Inspection Result: NOT READY

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND 58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL HOTEL * REVISION (1)
6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD PERIMETER
DRAINTILE * REVISION (2) - 9/13/2024 - ADDITIONAL ROOM & MOVE
BREAK ROOM

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: INSP FINAL COMMERCIAL - No Comments

Corrections:

- 1 1. Provide special inspection final report.
2. Provide backflow RPBA and PRV at commercial dishwasher.
3. Provide hammer arrestors at commercial washing machine.
4. Add double arrow to exit sign outside elevator lobby in hallway.
5. Provide 1" airgap in laundry linen closet.
6. Provide occupancy plaque in exercise room.
7. Provide 1" air gap in pool equipment room floor sink.
8. Repair gas valve handle for gas BBQ.
9. Insulate mechanical room per WSEC.
10. Paint curb north section of ADA parking.

Sincerely,

James LaVergne



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

JLaVergne@PuyallupWA.gov

(253) 841-5590