



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 13, 2025

Inspection Result: NOT READY

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND 58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL HOTEL * REVISION (1)
6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD PERIMETER
DRAINTILE * REVISION (2) - 9/13/2024 - ADDITIONAL ROOM & MOVE
BREAK ROOM

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 2 1. Provide special inspection report as well as engineering report.
2. Rope off back landing outside pool.
3. Investigate gas smell inside pool equipment room.
4. Finish mechanical room insulation.
5. Install RPBA and PRV at Kitchen dishwasher.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590