



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Aug 14, 2025

**Inspection Result:** NOT READY

**Permit Number:** PRCNC20241019

**Property Address:** 3303 8TH AVE SE, Unit: E, PUYALLUP, WA 98372;

**Contractor:** MOUNTAIN CONSTRUCTION 3411 90TH ST S; SUITE A LAKEWOOD,  
WA 98499 (253) 474-5281

**To construct:** Construct Early Learning Center

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. Fire caulking or fire foam finish.
2. Strap corner walls x 4.
3. Show anchor pin detail on interior walls.
4. Batten up fire blocking.

Sincerely,

James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590