



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 22, 2025 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMH20250723

Property Address: 3607 17TH ST SW, Unit: A, PUYALLUP, WA 98373;

Contractor: REFRIGERATION UNLIMITED 917 VALLEY AVE NW, STE E PUYALLUP, WA 98371

To construct: Installation of customer-provided Tucs cook chill system and multi-circuit rack. * REVISION (1) 7/15/2025 - ADDING CONCRETE HOUSEKEEPING PAD

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Provide Backflow certification. Provide UV protection on exterior line sets.

Corrections:

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590