



File No:	S2684
CCN:	UUFY
Issued:	6/16/2023
Revised:	6/16/2023

## CENTRAL STATION FIRE ALARM FIRE ALARM SYSTEM CERTIFICATE (NFPA 72)

**THIS CERTIFIES** that the *Alarm Service Company* is included by UL LLC in its Directory as qualified to use the *UL Listing Mark* in connection with the certificated *Alarm System*. This Certificate is the *Alarm Service Company's* representation that the *Alarm System* including all connecting wiring and equipment has been installed and will be maintained in compliance with requirements established by UL. This Certificate does not apply in any way to the installation of any additional signaling systems, such as; fire, smoke, waterflow, burglary, holdup, medical emergency, or otherwise, that may be connected to or installed along with the Certificated *Alarm System*. This Certificate does not apply in any way to the communication channel between the protected property and any facility that monitors signals from the protected property unless the use of a UL listed or Classified Alarm Transport Company is specified on the Certificate.

**LIMITATION OF LIABILITY:** UL LLC makes no representations or warranties, express or implied, that the Alarm System will in all cases prevent any loss by fire, smoke, water damage, burglary, hold-up or otherwise, or that the Alarm System will in all cases provide the protection for which it is installed or intended. By the Alarm Service Company providing this Certificate and the Protected Property acceptance of this Certificate, the Alarm Service Company and the Protected Property acknowledge and agree that UL does not assume or undertake to discharge any liability of the Alarm Service Company or any other party. UL is not an insurer and assumes no liability which may result directly or indirectly from inspection of the equipment, failure of the equipment, failure to conduct inspections, incorrect certification, nonconformity with requirements, failure to discover nonconformity with requirements, cancellation of the Certificate or withdrawal of the Alarm Service Company from inclusion in ULs Directory.

**OPERATIONAL REQUIREMENTS:** The *Alarm Service Company* bears the responsibility for the correctness of the installation; maintenance of the system documentation; periodic system inspection and testing; maintaining and providing any necessary repairs. All operations and maintenance shall be conducted in the manner prescribed by the NFPA standard referenced. All required service is to be provided for in an appropriate contract. System documentation is defined to include any "As Built Drawings"; the records of any "Acceptance Testing"; and the records of all periodic system testing and maintenance.

**ALARM SYSTEM DESCRIPTION:** This system is installed and operated in accordance with standard NFPA 72-2019

Authority Having Jurisdiction: Central Pierce Fire District  
Responding Fire Department: Puyallup Fire Department

### SYSTEM DEVIATIONS FROM REFERENCED NFPA STANDARDS

NONE

#### Protected Property:

SOUTH HILL BUSINESS & TECH CENTER  
1015 39TH AVE SE  
PUYALLUP, WA 98374 UNITED STATES

#### Alarm Service Company:

Everon LLC  
600 OAKESDALE AVE SW, SUITE 100  
RENTON, WA 98057 UNITED STATES

**SN: 161603.230616**



File No: S2684  
CCN: UUFY  
Issued: 6/16/2023  
Revised: 6/16/2023

## CENTRAL STATION FIRE ALARM FIRE ALARM SYSTEM CERTIFICATE (NFPA 72)

### Protected Property:

SOUTH HILL BUSINESS & TECH CENTER  
1015 39TH AVE SE  
PUYALLUP, WA 98374 UNITED STATES

### Alarm Service Company:

Everon LLC  
600 OAKESDALE AVE SW, SUITE 100  
RENTON, WA 98057 UNITED STATES

### Comments and Clarifications:

ENTIRE BUILDING COVERED

### Alarm System Description:

Authority Having Jurisdiction: Central Pierce Fire District  
Responding Fire Department: Puyallup Fire Department

### SYSTEM DEVIATIONS FROM REFERENCED NFPA STANDARDS

NONE

### Automatic Fire Detection and Alarm Devices

Coverage is Partial/Selective

Smoke Detector

195 Photo

Total: 195

### Sprinkler System and Supervisory Service

Sprinkler Type is Wet & Dry

Sprinkler Device

4 Waterflow Alarm Devices  
1 Control Valve Devices  
3 Air Pressure Devices  
10 SPRINKLER VALVE SUPERVISORY SWITCHES

Total: 18

### Manual Fire Alarm Devices

Manual Initiating Devices

23 Manual Fire Alarm Boxes / Station

Total: 23

### Alarm Notification and Annunciation Devices

Combination Signaling Devices/Notification Appliances

32 Horn / Strobe

Total: 32

Visual Only Signaling Devices/Notification Appliances

14 Strobe

Total: 14

### Control and Transmitter Unit:

Retransmission To Fire Department:

Primary Transmission Method:

Control Unit Manufacturer:

Control Unit Model:

Control & Transmitter Combo:

Secondary Transmitter Unit

Manufacturer:

Secondary Transmitter Unit Model:

Public Telephone Network  
Radio Frequency (RF) one-way  
SILENT KNIGHT  
6820  
No  
NFS-3030  
7788F

Monitoring Location:

UL Listed Central Station  
File: S1500  
SECURITAS TECHNOLOGY CORPORATION  
10025 S Tacoma Way, Suite H9  
Lakewood, WA 98499 UNITED STATES

**SN: 161603.230616**