City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 05, 2025 Inspection Result: PARTIAL PASS

Permit Number: PRCCP20240232

Property Address: 201 5TH AVE NE, PUYALLUP, WA 98372;

Contractor: DOCE LLC PO BOX 64160

TACOMA

To construct: Site development for proposed apartments (This permit submittal

replaces permit PRCCP20220417 due to design changes & new civil

construction permit needed per Ken Cook).

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Fire line was flushed. Flushed entire fire line from city main to 2" FDC. The building flange was jumped to the FDC flange.

- Fire line was flushed through 1 - 2.5" hose from the FDC with two bags for 15min. (PASSED)

Corrections:

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Jason Little
Development Engineering Inspector
JLittle@PuyallupWA.gov
(253) 244-0387