



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 09, 2025

Inspection Result: **FAILED**

Permit Number: PRCCP20230970

Property Address:

Contractor: MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

To construct: Civil Construction Permit for the East Town Crossing project associated with Preliminary Site Plan/SEPA, P-21-0034. 3002 E PIONEER

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The onsite roads are dirty and need to be kept clean.

The storm areas where residents are accessing is live and discharges to the stream.

After asking contractors they made arrangements to clean the asphalt. Thank you, this is a reminder. See corrections below and maintain them.

Corrections:

- 1 - Zero track out on to pavement where storm drainage is live.
- Keep all asphalt clean in construction areas.
- Zero track out on to Pioneer!

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387