



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Permit Review Correction Letter

Permit Application #PRCTI20251049

September 09, 2025

The City has completed the review of the above-mentioned permit submittal. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Re-submittal Instructions

To resubmit, you must address all comments and upload a ~~Correction Response Letter~~ that states how the corrections have been addressed in your resubmitted documents. Avoid using "upload additional docs" unless there is NO submittal item available for your document. Please Note: If you have any questions about how to resubmit, please contact the permit center.

- 1 Log in to your permits portal and navigate to the status page for this permit under the "My Items" tab by selecting the "Upload Submittals" button under the permit number.
- 2 For each submittal item listed re-submit a new version of the submittal item by clicking the "New Version" button next to the file name of the original file submitted. DO NOT click the 'browse' button unless the document you are submitting for that submittal item is not a new version of the originally submitted document. Click 'Upload Documents' at bottom of the page.
- 3 If any re-submittal fees have been assessed, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

Corrections

Corrections to be addressed on the next set of resubmitted plans:

Building Review	Ray Cockerham	(253)841-5585	RayC@PuyallupWA.gov
- See IBC 1013.1 Intervening means of egress doors within exits shall be marked by exit signs. Typ [CONSTRUCTION PLANS; 2025\PRCTI20251049\MultiCare Kitchen Expansion Phase 2 - Construction Set.pdf; pg. 2] - Cross connection protection to the ICE CUBE MAKER? [CONSTRUCTION PLANS; 2025\PRCTI20251049\MultiCare Kitchen Expansion Phase 2 - Construction Set.pdf; pg. 75] - Please verify that these are air gapped with make and model. Provided RPBA for no specification provided or pressure systems. UPC 603.5.10 Typical Brewers [CONSTRUCTION PLANS; 2025\PRCTI20251049\MultiCare Kitchen Expansion Phase 2 - Construction Set.pdf; pg. 75] - Please provide 506.3.8 Grease duct cleanouts and openings. Details and locations. [CONSTRUCTION PLANS; 2025\PRCTI20251049\MultiCare Kitchen Expansion Phase 2 - Construction Set.pdf; pg. 57] - Unable to locate this detail in the structural plans. TYP, for equipment. [CONSTRUCTION PLANS; 2025\PRCTI20251049\MultiCare Kitchen Expansion Phase 2 - Construction Set.pdf; pg. 60] - Project Specifications, - not included in submittal If project specifications are the same from one phase to the next please add this reference to the cover sheet with a publication date or other version details. Also indicate which phase this is submitted as part of the record (reference permit number) [CONSTRUCTION PLANS; 2025\PRCTI20251049\MultiCare Kitchen Expansion Phase 2 - Construction Set.pdf; pg. 1] - Acknowledgement requested. Cooler construction: Provide design professional seals for construction drawings for installation and inspection. Review submittal may be required, at inspectors discretion. [CONSTRUCTION PLANS; 2025\PRCTI20251049\MultiCare Kitchen Expansion Phase 2 - Construction Set.pdf; pg. 51] - Unable to find this sheet "SEE SHEET FS04-A.2." [CONSTRUCTION PLANS; 2025\PRCTI20251049\MultiCare Kitchen Expansion Phase 2 - Construction Set.pdf; pg. 44]			

- Cooler Compressor locations? Unable to locate roof plans with locations. [CONSTRUCTION PLANS; 2025\PRCTI20251049\MultiCare Kitchen Expansion Phase 2 - Construction Set.pdf; pg. 44]
- Required prior to construction; CONTRACTOR'S STATEMENT OF RESPONSIBILITY X X Acknowledgement requested. [CONSTRUCTION PLANS; 2025\PRCTI20251049\MultiCare Kitchen Expansion Phase 2 - Construction Set.pdf; pg. 18]

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, if "Resolved" means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City's permit portal](#).

Condition Category	Condition	Department	Condition Status
--------------------	-----------	------------	------------------

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center
(253) 864-4165 option 1
permitcenter@puyallupwa.gov