

PROJECT: 2ND STREET ADT		SHEET NO. 1/1
BY: CFA	DATE: 9/8/25	
JOB NO. 24112		

TO: CITY OF PUYALLUP BLDG DEPT
RE: 2ND STREET ADT

DRILLING NEW HOLES IN THE TJI
FLOORING WILL ADVERSELY EFFECT
THE STRENGTH OF THE FLOOR STRUCTURE.

