



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Permit Review Correction Letter

Permit Application #PRFA20251119

September 16, 2025

The City has completed the review of the above-mentioned permit submittal. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Re-submittal Instructions

To resubmit, you must address all comments and upload a ~~Correction Response Letter~~ that states how the corrections have been addressed in your resubmitted documents. Avoid using "upload additional docs" unless there is NO submittal item available for your document. Please Note: If you have any questions about how to resubmit, please contact the permit center.

- 1 Log in to your permits portal and navigate to the status page for this permit under the "My Items" tab by selecting the "Upload Submittals" button under the permit number.
- 2 For each submittal item listed re-submit a new version of the submittal item by clicking the "New Version" button next to the file name of the original file submitted. DO NOT click the 'browse' button unless the document you are submitting for that submittal item is not a new version of the originally submitted document. Click 'Upload Documents' at bottom of the page.
- 3 If any re-submittal fees have been assessed, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

Corrections

Corrections to be addressed on the next set of resubmitted plans:

Fire Review	David Drake	(253)864-4171	DDrake@PuyallupWA.gov
<p>1. Plans do not meet Total Coverage NFPA 72 requirements.</p> <p>2. Above ceiling smoke detection required. Use the Reflective Ceiling Building plans to determine all areas required. Most of the areas are in hallways or resident gathering areas. ACT is indicated on plans.</p> <p>3. Provide Attic plans for required Heat detection. Use the Building section view drawings to determine locations for detectors in hips, valleys, gable ends, outlooks that may not be visible on a 2D drawing.</p> <p>4. Game Room 1042: there is a tower that looks to be the height of all 3 floors? smoke detection will be required at the top and heat detection if there is attic space.</p> <p>5. Game Room 1042: the golf simulator looks to have drop beams that depending on the height will require a separate smoke detector. A cage will be required around this device.</p> <p>6. The following areas require smoke detection: 1030, 1032, 1033, 1035, 1037, 1040, 1041, 2035, 2037, 3036, 3037, please review all areas for code compliance.</p> <p>7. A remote annunciator is called out in the Legend. I do not see the location on the plans?</p> <p>8. Are the Local residential alarms separate from this system? If they are no further action will be required.</p> <p>9. Provide new layouts, battery calcs, and update device count on application.</p> <p>[Comment Correction; ; pg. N/A]</p>			

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, if "Resolved" means the condition has been fulfilled

successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City's permit portal](#).

Condition Category	Condition	Department	Condition Status
--------------------	-----------	------------	------------------

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center
(253) 864-4165 option 1
permitcenter@puyallupwa.gov