



(253) 926-1880 · FAX (253) 926-2350

SMITH FIRE SYSTEMS, INC.

1106 54th Avenue East · Tacoma, Washington 98424

September 17, 2025

Attention: Plan Review

Reference:

Marshal Office TI
302 33rd St SE
Puyallup, WA.

SFS Job #: TI25061

To whom it may concern:

This project is a tenant improvement. The facility has already been protected by a fire sprinkler system. Smith Fire is adding and/or relocating sprinkler heads to accommodate the new tenant wall, ceiling, lighting and HVAC layout. All work will be done without affecting the capability of the existing system; therefore, no new hydraulic calculations are necessary.

If you have any questions regarding this information, please contact me.

Sincerely,

Yili Chen
Designer
Smith Fire Systems, Inc.