



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 18, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRMU20240407

Property Address: 3002 E PIONEER BLDG C, PUYALLUP WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING A 3-story apartment building - EAST TOWN CROSSING -
REASSIGNED AS 3002 E PIONEER - BLDG C

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: See corrections.

Corrections:

- 1 - Maintain silt fence!
- Zero Track out!
- Use eco pan for concrete washout!

Sincerely,

Jason Little



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387