



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Permit Review Correction Letter

Permit Application #PRCTI20251104

October 01, 2025

The City has completed the review of the above-mentioned permit submittal. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below, please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Re-submittal Instructions

To resubmit, you must address all comments and upload a ~~Correction Response Letter~~ that states how the corrections have been addressed in your resubmitted documents. Avoid using "upload additional docs" unless there is NO submittal item available for your document. Please note: If you have any questions about how to resubmit, please contact the permit center.

- 1 Log in to your permits portal and navigate to the status page for this permit under the "My Items" tab by selecting the "Upload Submittals" button under the permit number.
- 2 For each submittal item listed, resubmit a new version of the submittal item by clicking the "New Version" button next to the file name of the original file submitted. DO NOT click the 'browse' button unless the document you are submitting for that submittal item is not a new version of the originally submitted document. Click 'Upload Documents' at the bottom of the page.
- 3 If any resubmittal fees have been assessed, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

Corrections

Corrections to be addressed on the next set of resubmitted plans:

Building Review	Brian Snowden	(253)435-3618	BSnowden@puyallupwa.gov
<p>- Plans to be revised with additional Bulk Storage. Please provide the revised plans set, along with structural plans and calculations and other relevant documents. [Comment Correction; ; pg. N/A]</p> <p>- Please correct the "Additional Commodity Info" note on sheet FE1. The current note references the 2018 IFC rather than the 2021 IFC. [Comment Correction; ; pg. N/A]</p> <p>- Please verify exit signage and egress lighting complies with sections 1013 and 1008 of the 2021 Washington State Building Code. Additional signage and lighting may be required to maintain distance and line-of-sight requirements within the proposed rack aisles. [Comment Correction; ; pg. N/A]</p>			
Fire Review	David Drake	(253)864-4171	DDrake@PuyallupWA.gov
<p>- 1. Provide emergency egress lighting page showing placement of lights and that it currently works with lighting layout or what changes will be made to illuminate the isles.</p> <p>2. Provide acknowledgment that fire alarm visual notification will be moved to the center of isles for direct line of site. If changes are required a Fire Alarm permit will be required. [Comment Correction; ; pg. N/A]</p>			

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, and if "Resolved" means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City's permit portal](#).

Condition Category	Condition	Department	Condition Status
Prior to Issuance	Contractor needs to have a valid City of Puyallup business license endorsement with the Washington State Department of Revenue.	Development & Permitting Services	Resolved

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov