



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 02, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCCP20241109

Property Address: 3303 8TH AVE SE, Unit: E, PUYALLUP, WA 98372;

Contractor: MOUNTAIN CONSTRUCTION 3411 90TH ST S; SUITE A LAKEWOOD, WA 98499 (253) 474-5281

To construct: This project will remodel and expand an existing auxiliary building to provide classrooms, outdoor learning spaces, administrative space, and office space. The project will be constructed over stormwater treatment BMPs that were installed to provide runoff treatment for the parking area installed during the 2018 Germaine Korum Center project. Therefore, this project will need to redesign/add runoff treatment BMPs to the existing parking area to replace the impacted treatment BMPs. See the attached Project Description. STEP BY STEP - ELC AND ADMINISTRATIVE OFFICES FACILITY

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Fire Line flush.

- Flushed fire line from main GV through a jumper between the building inlet flange and the building FDC flange to the outside FDC riser. 2 - 2.5" hoses for 15min. twice for a total of 30min. First flush had about 1 to 1.5 cups of pipe shavings from the tap. Second flush, bags were clean.

- Flushed underground 4" jumper between buildings from 1 - 2.5" hose off the hydrant. Flushed twice at 5min each. No debris.

All fire lines have PASSED flush.

Corrections:

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387