



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Permit Review Correction Letter

Permit Application #PRFUP20251233

October 02, 2025

The City has completed the review of the above-mentioned permit submittal. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Re-submittal Instructions

To resubmit, you must address all comments and upload a ~~Correction Response Letter~~ that states how the corrections have been addressed in your resubmitted documents. Avoid using "upload additional docs" unless there is NO submittal item available for your document. Please Note: If you have any questions about how to resubmit, please contact the permit center.

- 1 Log in to your permits portal and navigate to the status page for this permit under the "My Items" tab by selecting the "Upload Submittals" button under the permit number.
- 2 For each submittal item listed re-submit a new version of the submittal item by clicking the "New Version" button next to the file name of the original file submitted. DO NOT click the 'browse' button unless the document you are submitting for that submittal item is not a new version of the originally submitted document. Click 'Upload Documents' at bottom of the page.
- 3 If any re-submittal fees have been assessed, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

Corrections

Corrections to be addressed on the next set of resubmitted plans:

Engineering Review	Yianni Charitou	(253)435-3612	YCharitou@PuyallupWA.gov
- Site specific notes and other content on the site plan does not match the permit application for removing five poles. Redact any unrelated work from the site plan or update the project description on the application to match the proposed scope of work. [SITE PLAN ; 2025\PRFUP20251233\11X17 186054605 WORK SKETCH.pdf; pg. 1] - Remove this unnecessary sign. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 1] - Add a note for the pedestrian detour indicating which sheet the reciprocal detour sign is located on. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 1] - Add a note that permission must be granted by the private property owner in advance to place signs on private roadway. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 1] - Add a note that the flagger station shall be illuminated during night work. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 1] - Remove these unnecessary signs. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 2] - Three-sign advanced warning sequence required on 10TH ST SE. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 3] - This particular sign should read RIGHT TWO LANES CLOSED AHEAD. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 3] - Signs are cutoff on page. Adjust TCP accordingly. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 3] - Scope of work does not match permit application description. Pole removal not listed in P05 or P05A site specific notes on site plan. Update TCP accordingly or add a note that this TCP is not to be used for this particular permit. Do not delete page from TCP upon resubmission. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 4] - Three-sign advanced warning sequence required for westbound traffic on 39TH AVE SE. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 5]			

- Like TCP pages 1-3, additional traffic control devices are required to shift traffic into the center turn lane. Revise cone configuration and signs accordingly. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 5]
- Add a note that the flagger station shall be illuminated during night work. [TCP ; 2025\PRFUP20251233\TCP_Puyallup (1).pdf; pg. 6]

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The "Condition Category" indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. "Condition Status" if "Open" means that the condition has not been fulfilled, if "Resolved" means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City's permit portal](#).

Condition Category	Condition	Department	Condition Status
--------------------	-----------	------------	------------------

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center
(253) 864-4165 option 1
permitcenter@puyallupwa.gov