

Fire Systems West, Inc.

206 Frontage Road North, Suite C • Pacific, Washington 98047-1023 • (253) 833-1248 • (253) 735-0113

CORRECTION RESPONSE LETTER #PRFA20251193

October 2ND, 2025

Attn: Fire Prevention
333 S Meridian
Puyallup, WA 98371

"Fire Review David Drake (253)864-4171 DDrake@PuyallupWA.gov

- 1. Approval is being given to change smoke detectors to heat detectors in shower areas to avoid false alarms. I'm not sure what the Hydro area is? If this room has a lot of moisture please change to a heat detector. [Comment Correction; ; pg. N/A]"

RESPONSE:

The plan set uploaded to the permit portal on 10/02/2025 has been revised to show that in place of smoke detectors, heat detectors will now be installed in shower areas to avoid any potential false alarms, as these rooms will have a lot of moisture.

Fire Systems West, Inc.



By: _____

Matt Carlman

Title: Fire Alarm Manager

10/2/2025