BACKFLOW PREVENTION ASSEMBLY TEST REPORT



WATER PURVEYOR Puyallup, City of ACCO				
ASSEMBLY ID/FILE #/UTILITY DEVICE #			Meter #	
NAME OF PREMISE 2902 Pioneer Way E Commercial Commercial				
SERVICE ADDRESS 2902 Pioneer Way E			Puyallup ZIP 98372	
CONTACT PERSON PHONE (253) 279-1892				79-1892
LOCATION OF ASSEMBLY North of building B in metal cover (Building E 2" domestic)				
DOWNSTREAM PROCESS DCVA X RPBA PVBA OTHER DC				
NEW INSTALL EXISTING REPLACEMENT REMOVED OLD SER.#				
APPROVED ASSEMBLY? YES \boxtimes NO \square PROPER INSTALLATION? YES \boxtimes NO \square				
MAKE OF ASSEMBLY Wilkins MODEL 350XL			SERIAL NO. <u>B484906</u> SIZE <u>2"</u>	
INITIAL	DCVA / RPBA	DCVA / RPBA	<u>RPBA</u>	PVBA / SVBA
TEST	CHECK VALVE NO.1	CHECK VALVE NO.2	OPENED ATPSID	AIR INLET
	CLOSED TIGHT X	CLOSED TIGHT X		OPENED AT PSID
PASSED X	LEAKED	LEAKED	#1 CHECKPSID	DID NOT OPEN
FAILED	2.5 PSID	2.4 PSID	AIR GAP OK?	DID NOT OPEN
	CLEAN REPLACE PART	CLEAN REPLACE PART	CLEAN REPLACE PART	CHECK VALVE
NEW				HELD AT PSID
PARTS				LEAKED
AND				CLEANED
REPAIRS				REPAIRED
TEST AFTER	CLOSED TIGHT	CLOSED TIGHT	RV EXERCISED	AIR INLET PSID
REPAIRS	LEAKED	LEAKED	OPENED AT PSID	1310
PASSED	l	PSID	#1 CHECK PSID	CHK VALVEPSID
AIR GAP INSPECTION: SUPPLY PIPE DIAMETER SEPARATION PASS FAIL				
DETECTOR METER READING				
LEFT SERVICE AS FOUND Isolation valve: Open X Closed SOV#1: Open X Closed SOV#2: Open X Closed				
REMARKS:				
Bypass Psi: Closed Tight Leaked LINE PRESSURE 45 PSI CONFINED SPACE?				
TESTERS SIGNATURE: CERT. NO. <u>B8319</u> DATE <u>08-14-25</u>				
TESTERS NAME PRINTED Braden (Richard) Stone TESTERS PHONE # 425-277-2888				
REPAIRED BY:		LIC N	NO	DATE
FINAL TEST BY:		CERT	. NO	DATE
CALIBRATION DATE 03-31-2025 GAUGE # 10201207 MODEL 845-5 SERVICE RESTORED YES X NO				