



Backflows Northwest, Inc.
(425) 277-2888

BACKFLOW PREVENTION ASSEMBLY TEST REPORT

WATER PURVEYOR Puyallup, City of ACCOUNT # _____
ASSEMBLY ID/FILE #/UTILITY DEVICE # _____ Meter # _____
NAME OF PREMISE 2902 Pioneer Way E Commercial ☐ Residential ☐
SERVICE ADDRESS 2902 Pioneer Way E Puyallup ZIP 98372
CONTACT PERSON _____ PHONE (253) 279-1892
LOCATION OF ASSEMBLY North side of building B. Along sidewalk in metal cover (Building B 2" domestic)
DOWNSTREAM PROCESS _____ DCVA ☒ RPBA ☐ PVBA ☐ OTHER DC
NEW INSTALL ☐ EXISTING ☒ REPLACEMENT ☐ REMOVED ☐ OLD SER.# _____
APPROVED ASSEMBLY? YES ☒ NO ☐ PROPER INSTALLATION? YES ☒ NO ☐
MAKE OF ASSEMBLY Wilkins MODEL 350 SERIAL NO. B485025 SIZE 2"

INITIAL TEST	DCVA / RPBA CHECK VALVE NO.1	DCVA / RPBA CHECK VALVE NO.2	RPBA	PVBA / SVBA AIR INLET
PASSED ☒	CLOSED TIGHT ☒	CLOSED TIGHT ☒	OPENED AT _____ PSID	OPENED AT _____ PSID
FAILED ☐	LEAKED ☐	LEAKED ☐	#1 CHECK _____ PSID	DID NOT OPEN ☐
	<u>2.0</u> PSID	<u>2.2</u> PSID	AIR GAP OK? _____	
NEW PARTS AND REPAIRS	CLEAN ☐ REPLACE ☐ PART _____	CLEAN ☐ REPLACE ☐ PART _____	CLEAN ☐ REPLACE ☐ PART _____	CHECK VALVE
	☐ ☐ _____	☐ ☐ _____	☐ ☐ _____	HELD AT _____ PSID
	☐ ☐ _____	☐ ☐ _____	☐ ☐ _____	LEAKED ☐
	☐ ☐ _____	☐ ☐ _____	☐ ☐ _____	CLEANED ☐
TEST AFTER REPAIRS	CLOSED TIGHT ☐	CLOSED TIGHT ☐	RV EXERCISED ☐	AIR INLET _____ PSID
PASSED ☐	LEAKED ☐	LEAKED ☐	OPENED AT _____ PSID	CHK VALVE _____ PSID
FAILED ☐	_____ PSID	_____ PSID	#1 CHECK _____ PSID	

AIR GAP INSPECTION: SUPPLY PIPE DIAMETER _____ SEPARATION _____ PASS ☐ FAIL ☐
DETECTOR METER READING _____
LEFT SERVICE AS FOUND Isolation valve: Open ☐ Closed ☒ SOV#1: Open ☒ Closed ☐ SOV#2: Open ☒ Closed ☐

REMARKS:

Bypass Psi: Closed Tight ☐ Leaked ☐ LINE PRESSURE 45 PSI CONFINED SPACE? _____
TESTERS SIGNATURE: [Signature] CERT. NO. B8319 DATE 08-14-25
TESTERS NAME PRINTED Braden (Richard) Stone TESTERS PHONE # 425-277-2888
REPAIRED BY: _____ LIC NO. _____ DATE _____
FINAL TEST BY: _____ CERT. NO. _____ DATE _____
CALIBRATION DATE 03-31-2025 GAUGE # 10201207 MODEL 845-5 SERVICE RESTORED YES ☒ NO ☐

I certify that this report is accurate, and I have used WAC 246-290-490 approved test methods and test equipment.