



REVISION NARRATIVE

To: Per Department as Noted Below
Building Division
333 S. Meridian
Puyallup, WA 98371

Date: 09/29/2025
Applicant: Jennifer Wyman
Email: JenniferWyman@twinstepsarch.com
Phone: 206 260 1199

Plan Check Number: PRCTI20251201
Project Address: 1601 INDUSTRIAL PARKWAY, SUITE 101/102
Project Name: Puyallup 1 - Finishing Room
Previous Submittal Date: 09/09/2025

The following plan check responses for Permit Comment Responses are shown clouded with Delta 1.

BUILDING COMMENTS - REVISION RESPONSES

Reviewed by: Brian Snowden

#	SHEET REF	PLAN CHECK COMMENT	TA RESPONSE
1		Additional Submittal Item Required: The new concrete pad is outside of the existing building. Please provide a site plan specifying the concrete pad and showing where it will be located.	<i>Sheet AS100 has been added with an overall site plan as well as an enlarged site plan addressing the pad location and required modifications.</i>
2		Please confirm whether new concrete pad will be level with the sidewalk. Otherwise, please include how means of egress will be maintained.	<i>Enlarged plan on AS100 shows egress being maintained via a sidewalk extension routing around the pad.</i>
3		Wall types are on sheet A510.	<i>Confirmed.</i>

// END OF SECTION

Thank you,
Kirsten



Kirsten Jones
Project Architect
TWINSTEPS ARCHITECTURE
kirstenjones@twinstepsarch.com
O. [206 260 0226](tel:2062600226)

Denver • Irvine • Los Angeles • San Jose • Seattle
twinstepsarch.com