



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 17, 2025

Inspection Result: **FAILED**

Permit Number: PRFUP20250600

Property Address: 4227 S MERIDIAN, Unit: A, PUYALLUP, WA 98373;

Contractor: CABLECOM LLC 1429 Avenue D, #339 SNOHOMISH, WA (360) 920-3821

To construct: MAINTENANCE: SPLICE IN EXISTING CASES IN 2 LOCATIONS. UPGRADE VAULT IN 1 LOCATION.

On this day we have inspected your construction for **Closeout All Work Complete (No Restoration) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The contractor installed an additional vault rather than replacing it per the approved plan. **CORRECTION:** The backfill material around the new vault has settled. Remove larger rocks left over from excavation and add suitable backfill material, compact it and topsoil to match the existing landscape area. Coordinate with inspector for approval / sign-off.

Corrections:

Sincerely,

Cheryl Trimble
Development Engineering Inspector
CTrimble@PuyallupWA.gov
(253) 290-9834