



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 21, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20250324

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 773-3360

To construct: Commercial tenant improvement to existing 50,767 sf space - COP ~ PUBLIC SAFETY BUILDING * REVISION (1) - 8/21/2025 - GENERATOR DEFERRED SUBMITTAL

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: High wall first layer screw section A okay.

Corrections:

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590