City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 21, 2025 Inspection Result: PARTIAL PASS

Permit Number: PRCNC20241917

Property Address:

Contractor: E M PRECISION LLC 1407 VALENTINE AVE SE, STE 105 PACIFIC, WA

98047 (253) 268-0742

To construct: Ground up construction of a McDonald's with a Drive Through. -

MCDONALD'S - EAST TOWN CROSSING - 731 SHAW RD

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1 Complete nailing of hangers at exterior walls. (inspection of walls only)

Sincerely,

Shannon King Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684