



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Oct 15, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCNC20241917

**Property Address:** 731 SHAW RD, PUYALLUP, WA 98372

**Contractor:** E M PRECISION LLC 1407 VALENTINE AVE SE, STE 105 PACIFIC, WA 98047 (253) 268-0742

**To construct:** Ground up construction of a McDonald's with a Drive Through. -  
MCDONALD'S - EAST TOWN CROSSING - 731 SHAW RD

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Install hammer arrestors at both urinal and toilets

**Corrections:**

Sincerely,

James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590