



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Oct 23, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRMU20240401

**Property Address:** 3002 E PIONEER, BLDG E, PUYALLUP, WA 98372

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** ISSUED AS BUILDING D 3-story apartment building - EAST TOWN

CROSSING - REASSIGNED AS 3002 E PIONEER - BLDG E \* REVISION (1) -  
04/21/2025 - ENGINEERED TRUSS DRAWINGS

On this day we have inspected your construction for **Firewall/Firestop Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; units 104&204 complete fire caulk at kitchen and bathroom ceiling at mechanical chases.
  - 2 ; complete drywall at units 202&302 at mechanical chases of closet.
- ok to cover except areas noted.

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)