



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 30, 2025

Inspection Result: **FAILED WITH FEE**

Permit Number: PRMU20240406

Property Address: 3002 E PIONEER, BLDG D, PUYALLUP WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: ISSUED AS BUILDING F 3-story apartment building - EAST TOWN
CROSSING - REASSIGNED AS 3002 E PIONEER - BLDG D

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Incomplete fire taping behind tubs.

Corrections:

- 1 1 ; cancel per contractor - not ready
- 2 1. Incomplete fire taping behind tubs.
2. Vapor barrier not complete.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590