



NO	DATE	BY	REVISIONS
----	------	----	-----------

COMPOSITE UTILITY PLAN

MCD PUYALLUP
CIVIL PLANS

CITY OF BIYALILIP
WASHINGTON

3/20/25

JOB NUMBER:
24006004

SHEET NAME
CU-0

SHT 11 OF 16

Inaccurate underground utility plan. Please submit the plans that match the approved PRCCP20241846 permit which have an issue date of 5/7/2025.

PRSG20251040

1. FOOTING DRAINS TO BE 4" PERFORATED PIPE IN 3" OR 1 1/2" WASHED ROCK WRAPPED W/ MIRA11 140N OR APPROVED EQUAL AND INSTALLED AT A SLOPE OF 0.005.
2. CLEANOUTS IN SIDEWALKS OR DRIVE AISLES SHALL HAVE CAST IRON RING AND COVER SET FLUSH WITH FINAL GRADE.
3. CLEANOUTS IN SOFT AREAS TO RECEIVE CONCRETE COLLARS.
4. BENDS, WYES, ETC. (AS NECESSARY) TO BE DETERMINED BY CONTRACTOR.
5. FOOTING DRAINS TO BE LAID FLAT OR WITH POSITIVE SLOPE TOWARDS CONNECTION TO PROPOSED STORM SYSTEM.
6. CLEANOUTS SHALL BE PROVIDED EVERY 100' OR 135' IN DIRECTIONAL CHANGE.

EXISTING UTILITIES ARE SHOWN IN THE APPROXIMATE LOCATION. THERE IS NO GUARANTEE THAT ALL UTILITY LINES ARE SHOWN, OR THAT THE LOCATION, SIZE AND MATERIAL IS ACCURATE. THE CONTRACTOR SHALL UNCOVER ALL INDICATED PIPING WHERE CROSSING, INTERFERENCES, OR CONNECTIONS OCCUR PRIOR TO TRENCHING OR EXCAVATION FOR ANY PIPE OR STRUCTURES, TO DETERMINE ACTUAL LOCATIONS, SIZE AND MATERIAL. THE CONTRACTOR SHALL MAKE THE APPROPRIATE PROVISION FOR PROTECTION OF SAID FACILITIES. THE CONTRACTOR SHALL SUBMIT A PROTECTION PLAN TO THE OWNER (info@hmc.com) AND ABRANGE FOR FIELD LOCATION OF EXISTING FACILITIES BEFORE CONSTRUCTION.

10101010

DEVELOPMENT ENGINEERING

©2025 ATWELL NW