



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Nov 05, 2025                      **Inspection Result:**     **FAILED**

**Permit Number:** PRCTI20250537

**Property Address:** 302 33RD ST SE, PUYALLUP, WA 98372;

**Contractor:** DELANEY CONSTRUCTION LLC 635 TRADE CTR CHESTERFIELD, MO 63005

**To construct:** OFFICE TI; SCOPE TO INCLUDE BUILDING & MECH; EXISTING LARGE OFFICE SPACE- TO BE CONVERTED TO SEVERAL SMALL OFFICES; FULL HEIGHT PARTITIONS; CREATE ADDITIONAL OFFICE & STORAGE SPACE; REVISED ALL LIGHTING BUILD/MECH COMBINED

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

1. Debris on top of ceiling grid.
2. Electrical bracing and open electrical box not attached to ceiling grid.
3. Duct registers must be attached to T-bar main run as well as opposite side.
4. New heat duct must be insulated.
5. Spreader bars and burk clips must be installed.
6. Provide at least three turns of support wire for light fixtures.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590