



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 06, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20250117

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 773-3360

To construct: Voluntary Seismic Upgrade of the entire building from a Category 2 to a Category 4 - COP PUBLIC SAFETY BUILDING * REVISION (1) - 6/24/2025 - BRB (BUCKLING RESTRAINED BRACES AND CONNECIONS) SUBMITTAL * REVISION (2) - 7/16/2025 - CD SET AS A REVISON TO THE CURRENT SET

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: south elevation envelope nailing complete.

Corrections:

Sincerely,



Shannon King
Building Inspector 2

ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org